



CERTIFICATE OF ANALYSIS

East County Health Laboratory

Report Prepared For:

Report Dated: 8/3/2010

John and Jane Doe
100 Main St.
Anytown, US

Order No.: G1058

Laboratory ID#: 123500

Description: Water – Drinking Water

Sampling Location: 100 Main St., Anytown, US
Map 30 Parcel 10

Collected: 10/11/12
Received: 10/11/12

Routine

<u>Item</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method#</u>	<u>Tested</u>
Nitrate as Nitrogen	ND	mg/L	0.10	10	EPA300.0	10/11/12
Copper	0.11	mg/L	0.10	1.3	SM3111B	10/12/12
Iron	ND	mg/L	0.10	0.3	SM3111B	10/12/12
Sodium	21	mg/L	2.5	20	SM3111B	10/12/12
Total Coliform	Absent	P/A	0	0	SM9223	10/11/12
Conductance	160	umohs/cm	2.0		EPA 120.1	10/11.12
pH	6.3	pH-units	0		SM 4500 H-B	10/11/12

Sodium level is above the maximum contamination level. Those of a low-sodium diet may wish to consult a physician.

Approved By:

(Lab Director)

10/15/12

ND = None Detected

RL = Reporting Limiting

MLC = Maximum Contaminant Level